



Attestation of Compliance

No. E8N 11 07 73342 015

Holder of Certificate: **Sungrow Power Supply Co., Ltd.**
 No. 2 Tianhu Road, New & High
 Technology Industrial Development Zone,
 230088 Hefei, Anhui
 PEOPLE'S REPUBLIC OF CHINA

Name of Object: **Converter**
PV Grid Connected Inverter

Model(s): **SG1K5TL-31**

Description of Object:

Input voltage:	DC 150V~450V
Max. input power:	1.65KW
Rated output voltage:	AC 230V
Rated frequency:	50Hz
Rated output power:	1.5KW
Protection class:	I

Tested according to: EN 61000-6-3:2007
 EN 61000-6-2:2005

This Attestation of Compliance is issued according to the Directive 2004/108/EC relating to electromagnetic compatibility on a voluntary basis. It confirms that the listed apparatus complies with all essential requirements of the EMC directive and applies only to the sample and its technical documentation submitted to TÜV SÜD Product Service GmbH for testing and certification. See also notes overleaf.

Test report no.: 4841011231300

Date, 2011-08-16 (Xiao Liu)



CE After preparation of the necessary technical documentation as well as the EC conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.