



Product Service

Attestation of Compliance

No. E8N 10 03 73342 001

Holder of Certificate: **Sungrow Power Supply Co., Ltd.**

No. 2, Tianhu Road
 High and New Technology Development Zone
 230088 Hefei, Anhui
 PEOPLE'S REPUBLIC OF CHINA

Name of Object: **Converter
 PV Grid Connected Inverter**

Model(s): **SG3KTL, SG4KTL**

Description of Object:

Rated input voltage:	150-550V DC
Rated input power:	3.3kW [SG3KTL] 4.4kW [SG4KTL]
Rated output voltage:	230V AC
Rated frequency:	50Hz
Rated output power:	3kW [SG3KTL] 4kW [SG4KTL]
Protection class:	I

Tested according to: EN 61000-6-1:2007
 EN 61000-6-3:2007

This Attestation of Compliance is issued according to the Directive 2004/108/EC relating to electromagnetic compatibility on a voluntary basis. It confirms that the listed apparatus complies with all essential requirements of the EMC directive and applies only to the sample and its technical documentation submitted to TÜV SÜD Product Service GmbH for testing and certification. See also notes overleaf.

Test report no.: 708880962601-00

Date, 2010-03-09 (Linda Qiu)



CE After preparation of the necessary technical documentation as well as the EC conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.