


# ATTESTATION OF CONFORMITY

Issued to: Sungrow Power Supply Co., Ltd.  
No.1699 Xiyou Rd., New & High Technology Industrial Development Zone, 230088,  
Hefei, P. R. China

For the product: Grid-connected PV inverter

Trade name: 

Type/Model: SG250HX

Ratings: PV input: Max. 1500 Vdc, MPPT voltage range: 600-1500 Vdc, max 12\*26 A,  
Isc PV: 12\*50 A  
Output: 3/PE, 800 Vac, 50 Hz, Rated output 225 kW, max 250 kVA, max 180.5 A

Manufactured by: Sungrow Power Supply Co., Ltd.  
No.1699 Xiyou Rd., New & High Technology Industrial Development Zone, 230088,  
Hefei, P. R. China

Requirements: G99 Issue 1 – Amendment 4:2019  
(Requirements for Type B, C and D Generating Module)

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no 6068396.50.


The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Arnhem, 19 January 2020

Number: 6068396.01AOC

DEKRA Testing and Certification (Shanghai) Ltd.

Kreny Lin  
Certification Manager



© Integral publication of this attestation and adjoining reports is allowed

DEKRA Testing and Certification (Shanghai) Ltd.  
3F #250 Jiangchangsan Road Building 16 Headquarter Economy Park Shibe Hi-Tech Park, Jing'an District, Shanghai 200436 China  
T +86 21 6056 7600 F +86 21 6056 7555 www.dekra-certification.com